

# THE ENERGY EVANGELISTS (EnergyPlus Team)

## ASHRAE LowDown Showdown

### SimBuild 2016 Conference

Building Type: Healthcare  
Total Floor Area: 50,000 ft<sup>2</sup>  
Number of Floors: 3  
Location: Omaha, Nebraska

#### Total Energy Usage

**2,745** MWh

#### Site EUI

**694** kWh/sq.m.

#### Source EUI

**871** kWh/sq.m.

#### Annual Electricity Usage

**318** MWh

#### Annual NG Usage

**2,427** MWh of BIO GAS

#### Annual Water Usage

**3,353** Cubic Metres

#### Annual Electricity Cost

**-25,080** \$

#### Annual NG Cost

**12,066** \$

#### Annual Water Costs

**18,318** \$

#### Total Annual Costs

**5,304** \$

#### CPSF

#### Total Energy Generation

**3,126** MWh

#### Net Zero Energy

#### Carbon Equivalent

**- 215,825** Pounds

### Team


Vice Captain	<b>Amir</b> Rezaei-Bazkiaei
Lighting Design/Water Use	<b>An-Lei</b> Huang
Envelope optimization	<b>Arfa</b> Aijazi
Energy Modeler	<b>Jason</b> Kirkpatrick
Internal Loads Design	<b>Matthew</b> Dahlhausen
Fan	<b>Matthew</b> Larson
Mechanical Engineer	<b>Vinay</b> Devanathan
Captain	<b>Annie</b> Marston
Coach/Architect	<b>Harshul</b> Singhal



### Model Description

The proposed design has a circular form with easy access to critical areas and 30% window-to-wall ratio. An efficient dedicated outdoor air system (DOAS) equipped with a desiccant heat recovery wheel and an evaporative cooler provides fresh air to all the zones. Chilled water (CW) and hot water (HW) coils were selected for the DOAS unit. Four-pipe chilled and heated beams provide zone conditioning. A few high load zones were equipped with supplemental CW fan-coil units to satisfy thermal comfort. PV and combined heat and power (CHP), fed by local bio-gas from a landfill, provide the entire building electricity demand with 26% surplus energy fed back to the grid annually.

### Annual Energy Cost Comparison



LDSd Results Summary	Baseline	Proposed Design
Total Energy Usage (MWh)	1,409	2,745
Site EUI (kWh/m2)	356	694
Source EUI (kWh/m2)	1,038	871
Annual Electricity Usage (MWh)	1,069	318
Annual Natural Gas Usage (MWh)	340	2427 (bio-gas)
Annual Water Usage (m3)	509	3,353
Annual Electricity Cost (\$)	81,111	(25,080)
Annual NG usage (\$)	2,209	12,066
Annual Water Costs (\$)	2,760	18,318
Total Energy Generation (MWh)	-	3,162
Carbon Equivalent (lbs Ceq)	1,659,504	(215,825)

### Energy Savings Strategies

- The compact circular building form provides ample daylight while minimizing the exterior exposure.
- A very tight envelope (0.1 CFM/ft<sup>2</sup> infiltration) with R-40 roof, R-40 wall and triple pane windows (U-0.18 Btu/hr.ft<sup>2</sup>.F, SHGC-0.2, VT-0.7) combined with medium thermal mass reduces the HVAC loads.
- LED lighting for the entire building and daylight sensors for all the perimeter spaces.
- Thorough research was performed on internal loads and key strategies targeted elevator, medical equipment and office computer loads.
- DOAS has a desiccant heat wheel and evaporative cooler to minimize heating and cooling energy.
- Both DOAS and four-pipe beams' CW/HW coils take advantage of a central water plant heat recovery with a micro-turbine and an absorption chiller.

### Design features

1. Panels tilted at 35 degree facing south direction – provides shade from the direct glare. Also, increases the yield of the electricity.
2. Semi-covered spaces for the patients
3. Optimized shape of the building
4. Street/exterior lighting with PV panels
5. Green roof
6. Optimized shading devices

